

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 714

Dated: 25-06-2025

It is certified that an inspection team headed by Er. Sudhir Kumar Pruthi, SDE(Name of Officers with designation) from Department of Water and Sanitation(Name of Department/ Office) inspected the AKAL Academy Manawan(Name & Address of the school) on 25.06.2025 (date of inspection) and found that the AKAL Academy Manawan (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.The above is valid for a period of 25.06.2025 to 31.03.2026Signature with Seal: Sub Divisional Engineer

Name

Designation

Water Supply & SanitationSub Divisional Engineer (Moga)Sub Divisional Engineer

Name &amp; Address of the Office / Department : .....


To

AKAL AcademyManawan

(Name &amp; Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

  
**Manager**  
**AKAL Academy**

  
**Headmistress**  
**AKAL ACADEMY**  
**Manawan (Moga)**



# REGIONAL WATER TESTING LAB, MOGA

Near BSNL exchange, water works, Moga (Ajitwal)  
rwtlmoga@gmail.com



TC-12929

## TEST REPORT

Name & Address of Customer : <b>Akal Academy Manawan, Moga</b>			Customer Reference No.		No : Ref No. MAN.T.2025-26/447 Dated : <b>17/04/2025</b>	
			Sample Submitted by		<b>Navjot Singh</b>	
			Date of Sample Receipt		<b>17/04/2025</b>	
			Analysis Starting Date		<b>24/04/2025</b>	
			Analysis completion Date		<b>25/04/2025</b>	
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:		<b>TC129292500000218F</b>		Sample Type :		<b>Water</b>
Test Report No.:		<b>RWTLMOG/2526/00038</b>		Date of Issue :		<b>28/04/2025</b>
Registration no.:		<b>RWTLMOG/REG2526/00042</b>		Condition of Sample :		<b>Unsealed</b>
Collection Point:		<b>Private Submersible</b>		Quantity/Type of Bottle:		<b>1000 ml / Plastic Bottles</b>
Scheme/Source:		<b>Not Mentioned(Not Mentioned)</b>		Location/Depth :		<b>School Motor Water depth 420ft ( akal Academy Manawan) / 420 ft</b>
Village :		<b>Manawan</b>		Habitation :		<b>Manawan</b>
Block:		<b>Dhramkot</b>		District :		<b>Moga</b>
Latitude :		<b>Not Mentioned</b>		Longitude:		<b>Not Mentioned</b>

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.39@26°C	6.5-8.5	No Relaxation	—	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	—	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	—	IS 3025 (Part 8 – 2023)
5	TDS	312	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	260	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	40	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	8	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	5	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	30	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report Is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

*Ashish Kumar*

Ashish Kumar

Sr. Chemist

Authorized Signatory

For,Regional Water Testing Lab  
Moga

End of the Test Report

*[Signature]*  
Manager  
**AKAL ACADEMY**  
Manawan (Moga)

*[Signature]*  
Headmistress  
**AKAL ACADEMY**  
Manawan (Moga)