

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 332Date: 07/05/2026


It is certified that an inspection team headed by Er. Sudhis Kumar Pruthi, SPE (Name of Officers
Sub Divisional Engineer, Water Supply & Sanitation, Dharamkot (Name of
with designation) from Water Supply and Sanitation, Dharamkot (Name of
Department/Office) inspected the Akal Academy Manawan
_____ (Name & Address of
the School) on 07/05/2026 and found that the Akal Academy Manawan
_____ (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 07/05/2026 to 31/03/2027

Signature with Seal

Name

Designation


Er. Sudhis Kumar Pruthi
Sub Divisional Engineer

To

Akal AcademyManawanDISTRICT MOGA

(Name & Address of the Institution)


Manager
AKAL ACADEMY
Manawan (Moga)


Headmistress
AKAL ACADEMY
Manawan (Moga)

REGIONAL WATER TESTING LAB, MOGA

Near BSNL exchange, water works, Moga (Ajitwal)
rwlmoga@gmail.com

TEST REPORT

Name & Address of Customer : Akal Academy Manawan Tehsil Dharamkot Distt Moga (Punjab)		Customer Reference No.	No : Ref. No. - Man/T/2026-27/508 Dated : 16/04/2026	
		Sample Submitted by	Harpreet Singh	
		Date of Sample Receipt	24/04/2026	
		Analysis Starting Date	25/04/2026	
		Analysis completion Date	27/04/2026	
Discipline : Chemical Testing		Group: Water		
ULR No.:		Sample Type :	Water	
Test Report No.:	RWTLMOG/2627/00086	Date of Issue :	28/04/2026	
Registration no.:	RWTLMOG/REG2627/00542	Condition of Sample :	Unsealed	
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Academy Motor Water (Akal Academy Manawan) / NA	
Village :	Manawan	Habitation :	Manawan	
Block:	Dhramkot	District :	Moga	
Latitude :	Not Mentioned	Longitude:	Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.04@27°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	427	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	232	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	40	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	8	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	5	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	18	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Ashish Kumar

Ashish Kumar
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Moga

End of the Test Report

Basinder
Manager
AKAL ACADEMY
Manawan (Moga)

Han
Headmistress
AKAL ACADEMY
Manawan (Moga)
Page No. 1/1